



GREATER VISAKHAPATNAM MUNICIPAL CORPORATION
FIRE PREVENTION WING

From,
The Commissioner,
Greater Visakhapatnam
Municipal Corporation
Visakhapatnam.

To,
The District Educational Officer,
Visakhapatnam District,
Visakhapatnam.

Rc.No.301/RFO/FPW/GVMC/2022, Dt.10-08-2022.

SUB: Greater Visakhapatnam Municipal Corporation - Fire Prevention Wing - Existing Building of **M/s.Adarsh Public School, D.No.24-28-1, Vinayak Nagar, Pedagantyada, Visakhapatnam - Fire No Objection Certificate for Occupancy** - Issued - Reg.

REF: 1. Letter Rc.No: 5041/B2/97 of Director General, A.P Disaster Response & Fire Services Department, Dated: 12-03-2010.
2. Delegation orders of the Commissioner, GVMC vide Rc.No.6721/2012/TP. Sec/G1 Dt:13/09/2019.
3. Application Dt.02-08-2022 of M/s.Adarsh Public School, D.No.24-28-1, Vinayak Nagar, Pedagantyada, Visakhapatnam for Fire No Objection Certificate for Occupancy.

It is to inform that, vide reference 3rd cited, an application is received by this office for issuance of Fire No Objection Certificate for Occupancy to the existing building of M/s.Adarsh Public School, D.No.24-28-1, Vinayak Nagar, Pedagantyada, Visakhapatnam.

2. Therefore, the Station Fire Officer, Fire Prevention wing, GVMC inspected the premises of M/s.Adarsh Public School, D.No.24-28-1, Vinayak Nagar, Pedagantyada, Visakhapatnam on 08-08-2022 and submitted the following report.

3. Particulars of the building:

a)	Address of the Premises	M/s.Adarsh Public School, D.No.24-28-1, Vinayak Nagar, Pedagantyada, Visakhapatnam
b)	Total Plot Area	4937.00 Sq. Mtrs.
c)	Height of the Building	96.00 Mtrs. 3.00 Mtrs. 10/8/2022
d)	No of blocks/ floors	Ground Floor only
e)	Type of occupancy	Educational (School)

4. The floor wise details.

Sl. No.	Floor	Area in Sq. Meters.	Type of Occupancy
1	Ground	985.00	Educational (School)
	Total	985.00	

5. The builder has provided the following open spaces surrounding the building:

Side	Open spaces provided by the builder in Meters
North	06.00
South	03.00
East (Front)	06.00
West	03.00

6. Details of Means of escape provided in the Building:

- The management provided sufficient no. of doors.

7. The details of Fire Fighting Equipment required and provided by the builder.

Sl. No.	Fire Safety Measures	Required	Provided	Deficit
1.	Fire Extinguishers as per IS 2190	10 Nos.	10 Nos.	Nil
2.	Terrace Tank	5,000 Ltrs.	5,000 Ltrs.	Nil
3.	Fire Buckets	04 Nos.	04 Nos.	Nil



Contd..page.2